

UL Online Certifications Directory

GSXZ.R21720 Special Purpose Type Fire Doors

[Page Bottom](#)

Special Purpose Type Fire Doors

[See General Information for Special Purpose Type Fire Doors](#)

ALUFLAM NORTH AMERICA L L C

R21720

PO BOX 16863

IRVINE, CA 92623 USA

Special purpose type fire door and frame assembly, with transom and or side lights, maximum rating 1 hr. May be installed into either gypsum wallboard or masonry walls. Overall frame size not to exceed 120 in. in height or in width.

Also Classified in accordance with UL10C, UBC 7-2 (1997).

[Last Updated](#) on 2006-03-21

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2006 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

