



Alumatec Pacific Products

1155 West 500 North
Centerville, UT 84014
Phone: 801-298-0181
Fax: 801-298-0905
Email: info@alumatecpp.com

SLIDING GRILLE CHECK LIST

- Opening widths & heights are the same as shown on shop drawings, if different please note:

- Clearance is at least 1" at the closest point from bottom of grille to floor.
- The grille does not hang up on the bottom V-angle at the pocket base.
- There is a minimum of 8" of pocket width. If less, please note:

- The grille does not have to be pulled tight to fasten the locks.
- All post locks operate freely without an excess amount of force to lock and unlock.
- All track seams have been aligned and pins are installed. There is no visible indication of warps or bends in the track.
- The grille runs smooth and to your satisfaction. If not, please note:

- Dust proof receptors for post lock are installed in floor.
- Final inspection and adjustment required at the time contractor turns the job over to client

SECURITY GRILLE IS INSTALLED AND FUNCTIONING PROPERLY!!

Date: _____
 Job Name: _____
 Location: _____ (Mall Name / City & State)
 Customer Representative's Signature: _____
 Installer's Signature: _____

**** IF CHECKLIST IS NOT RETURNED WITH YOUR INVOICE, PAYMENT WILL BE WITHELD****