

(1) COVER:14 GAUGE GALVANNEAL COVER STIFFENED

(3) CURB AND COUNTERFLASH W/ EZ TAB: 14 GAUGE

4 FINISH: COVER- POWDER COAT PAINT, ANSI 70 GRAY **CURB-** POWDER COAT PAINT, ANSI 70 GRAY

(5) **GAS SPRING WITH DAMPER**: DESIGNED TO OPEN AGAINST A 10PSF SNOW LOAD IN NOT LESS THAN 2 SECONDS (6) HOLD OPEN ARM: LOCK COVER IN FULLY OPEN POSITION -

 $\langle 7 \rangle$  LATCH: ZINC PLATED ROTARY LATCH ASSEMBLY DESIGNED

TO HOLD COVERS CLOSED AGAINST 30 PSF WIND UPLIFT

SPECIFICATIONS:

**GALVANNEAL** 

ZINC PLATED STEEL

**SECTION A-A** 



TO WITHSTAND A LIVE LOAD OF 40 PSF WITH A MAX AROUND CURB PERIMETER, R-VALUE 6 DEFLECTION OF 1/150 OF THE SPAN (10) GASKET: ADHESIVE BACKED EPDM RUBBER EXTRUSION (2) LINER: 22 GAUGE GALVANNEAL

(11) THERMAL RELEASE MECHANISM: VENT COVERS OPEN

(9) INSULATION: 1" POLYISOCYANURATE IN COVER AND


THERMALLY BY HEAT AT FUSIBLE LINK TEMPERATURE (12) MANUAL OPENING: VENT COVERS OPEN WITH INTERNAL AND


EXTERNAL MANUAL PULL HANDLE, 1/16" DIA SST CABLE

SMOKE VENT SIZE (WIDTH) x (LENGTH)

**EFFECTIVE VENTING AREA 90%** FT<sup>2</sup>


ZINC PLATED STEEL LATCH STRIKERS ON COVERS PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF NYSTROM. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF NYSTROM IS PROHIBITED.






	ROJEC	<i>,</i> 1.						
Α	RCHITE	CT:						
СО	NTRAC	TOR:						
	QTY:							
	PART#	<b>‡</b> :		svsg	Х	s	1N I	R
9300 7	Righ 73rd Aver	nt to site.  North MN 55428		Galva	oke Vent SmokE anneal, Sngl Dr, S	scape Sngl W	/all Curb	
	NAME	DATE	SIZE	DWG. NO.				REV
DRAWN	вмн	05/04/11	Α		SVSG_X_S1N	_R		Α
RELEASED	DS	05/04/11	WE	IGHT: VARIE	S		SHEET 1 (	OF 2

DDO IECT.





## SMOKE VENT COVER OPENS WHEN ACTIVATED BY:

A. THERMAL RELEASE MECHANISM: RELEASED BY HEAT WITH A UL LISTED FUSIBLE LINK AT TEMPERATURE

**OPTIONS:** 165 °F, 212 °F, 280 °F, 350 °F, 360 °F, 370 °F, 386 °F, 450 °F

B. MANUAL OPENING: RELEASED BY EXTERNAL AND INTERNAL PULL CABLES WITH HANDLES AND 5FT OF INTERNAL CABLE PROVIDED

## SMOKE VENT COVER CLOSED MANUALLY FROM ROOFTOP

NYSTRUM  Right to site.  9300 73rd Avenue North Brooklyn Park, MN 55428				TITLE: Smoke Vent SmokEscape Series Galvanneal, Sngl Dr, Sngl Wall Curb			
	NAME	DATE	SIZE	DWG. NO.		REV	
DRAWN	ВМН	05/04/11	Α	SVSG_X_S1N_R		A	
RELEASED	DS	05/04/11	WE	IGHT: VARIES	SHEET 2 (	OF 2	