





## **SECTION A-A**

## SPECIFICATIONS:

- (1) COVER: 11 GAUGE ALUMINUM STIFFENED

  TO WITHSTAND A LIVE LOAD OF 40 PSF WITH A MAX
  DEFLECTION OF 1/150 OF THE SPAN
- $\langle \overline{2} \rangle$  **Liner**: 18 gauge aluminum
- (3) CURB AND COUNTERFLASH W/ EZ TAB:11 GAUGE ALUMINUM
- 4 FINISH: COVER- MILL CURB- MILL
- (5) GAS SPRING WITH DAMPER: DESIGNED TO OPEN AGAINST A 10PSF SNOW LOAD IN NOT LESS THAN 2 SECONDS
- (6) HOLD OPEN ARM: LOCK COVER IN FULLY OPEN POSITION ZINC PLATED STEEL
- (7) LATCH: ZINC PLATED ROTARY LATCH ASSEMBLY DESIGNED TO HOLD COVERS CLOSED AGAINST 90 PSF WIND UPLIFT ZINC PLATED STEEL LATCH STRIKERS ON COVERS

- (8) HINGES: ZINC PLATED STEEL WITH STAINLESS STEEL HINGE PINS
- (9) INSULATION: 1" POLYISOCYANURATE IN COVER AND AROUND CURB PERIMETER, R-VALUE 6
- (10) GASKET: ADHESIVE BACKED EPDM RUBBER EXTRUSION
- THERMAL RELEASE MECHANISM: VENT COVERS OPEN
  THERMALLY BY HEAT AT FUSIBLE LINK TEMPERATURE °F
- 12 MANUAL OPENING: VENT COVERS OPEN WITH INTERNAL AND EXTERNAL MANUAL PULL HANDLE, 1/16" DIA SST CABLE

SMOKE VENT SIZE (WIDTH) x (LENGTH)

EFFECTIVE VENTING AREA 90% SQFT

ZINC PLATED STEEL LATCH STRIKERS ON COVERS
PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BABCOCK-DAVIS. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BABCOCK-DAVIS IS PROPRIETED.



8

PROJECT:								
ARCHITECT:								
CONTRACTOR:								
QTY:								
PART#:				BSVSA	Х	D11	N	R
Babcock-Davis 9300 73rd Avenue North Brooklyn Park, MN 55428				TITLE: Smoke Vent, SafeMAX Series Aluminum, Dbl Dr, Single Wall Curb Non-Electrical				
	NAME	DATE	SIZE	DWG. NO	•			REV
DRAWN	-	05/04/11	Α	BSVSA_X_D1N _R				-
RELEASED	DS	05/04/11	WE	WEIGHT: VARIES SI				OF 2



