

25DTPC

AMTPC Series

INSTALLATION INSTRUCTIONS

Components Included . . .

Communications Add-On Compartment
 Two Trim Plates
 One Entrance End Plate
 Two Grommets

Communication Capacities

Communication Cables- No. of Pairs		25	4
No. of Cables	30% Fill	9	40
	60% Fill	18	80

25DTPC Series

1. Remove pole entrance end plate.
2. Remove communications compartment.
3. Snap on 25DTPC to divider.
4. Snap on communications compartment to 25DTPC.
5. Screw on entrance plate (provided).
6. Remount pole.

AMTPC Series

1. Remove pole entrance end plate.
2. Snap on AMTPC to side of communications compartment.
3. Screw on entrance end plate (provided).
4. Remount pole.

Wiremold Electrical Systems conform to and should be properly grounded in compliance with requirements of the current National Code or codes administered by local authorities.

All electrical products may represent a possible shock or fire hazard if improperly installed or used. Wiremold electrical products are UL listed, made for interior use in dry locations only and should be installed in conformance with current local and/or the National Electrical Code.

